

UK Declaration of Conformity

- MULTICAL® 403 2
- Kamstrup Pt500 Temperature Sensors 3
- Kamstrup Temperature Sensor 63/83 4





UK DECLARATION OF CONFORMITY

The UKCA (UK Conformity Assessed) marking is a product marking used for goods being placed on the market in Great Britain (England, Wales and Scotland). It covers goods which previously required the CE marking, known as 'new approach' goods.

Kamstrup A/S
 Industrivej 28, Stilling
 DK-8660 Skanderborg
 T: +45 89 93 10 00
 F: +45 89 93 10 01
 M: kamstrup@kamstrup.com

We, Kamstrup A/S declare that this Declaration is issued under our sole responsibility and belongs to the following product: **MULTICAL® 403**, Ultrasonic Heat, Cooling and Heat/Cooling meter, type number 403XXXXXX-XXXXX (Note 1 applies), serial number XXXXXXXX/XX/23, which is in conformity with the latest versions of the relevant UK Regulations, as marked below:

The Restriction of the Use of Certain Hazardous Substances in Electrical and Electronic Equipment Regulations 2012, standard: EN/IEC 63000:2018.

Electromagnetic Compatibility Regulations 2016, standards: EN 61326-1:2013 and EN 61326-1:2021.

Applies to type numbers: 403-xxxxx-xxx**00/10/11/20/21/22/40/42/43/66/67/81/82/83**.

Measuring Instruments Regulations 2016, standards: EN 1434:2007/AC:2007, EN 1434:2015/A1:2018/A1:2019, EN 1434:2022, WELMEC 7.2:2022.

Applies for products marked with CE marking and supplementary metrology marking according to Article 21 in directive 2014/32/EU. Module B certificate number: DK-0200-MI004-037.

Notified Body, Module D certificate: FORCE Certification A/S, EU Notified Body number: 0200, Park Allé 345, DK-2605 Brøndby. Module D certificate number: DK-0200-MID-D-001.

Electrical Equipment (Safety) Regulations 2016, standard: EN 61010-1:2010 and EN 61010-1:2010/A1:2019.


Radio Equipment Regulations 2017, standards: EN 300 220-2 v.3.1.1:2017, EN 301 489-1 v2.2.3:2019, EN 301 489-3 v2.1.1:2019, EN 301 511 v1.2.1.10, EN 301 908-1 v11.1.1, EN 301 908-13 v13.1.1, EN 62311:2020, EN 301 489-52 v1.1.0. Applies to type numbers: 403-xxxxx-xxx**30/31/32/33/50/51/53/56/58**

Pressure Equipment (Safety) Regulations 2016, standard: EN 13480-3:2017. PS: 25 bar, TSmax: 130 °C, TSmin: 2 °C. Fluid group 2, category 4§3 (regulation 8) and category I + module A. Conformity assessment procedures according to regulation 41. Products that fall under regulation 8 shall not be UK-marked.

Notified body, Quality system ISO 9001: DNV, Tuborg Parkvej 8, 2., DK-2900 Hellerup.

Date: 2022-12-23, Skanderborg

Senior Vice President, Technology:



Anders Skallebæk

Note 1. The type number of the meter

The type number consists of two parts, a 9-digit static part and a 5-digit dynamic part. The static part of the type number is printed on the front of the meter, while the dynamic part of the type number can be viewed in the display.

To evoke the dynamic part of the type number, press the primary key and hold it down until the text 2 – TECH becomes visible in the display. Release the primary key briefly and subsequently use it to shift forward until index number 2-018-00 is visible in the display. Now use the secondary key to shift forward until index number 2-018-09 is visible in the display, release the key and the dynamic part of the type number will be visible in the display with reference N° 21 in the display's upper right corner.



Primary key



Secondary key

Note: In the event of inconsistency or discrepancy between the English version and any other language version, the English version shall prevail.

No.: 5518513_B1



UK DECLARATION OF CONFORMITY

The UKCA (UK Conformity Assessed) marking is a product marking used for goods being placed on the market in Great Britain (England, Wales and Scotland). It covers goods which previously required the CE marking, known as 'new approach' goods.

Kamstrup A/S
Industrivej 28, Stilling
DK-8660 Skanderborg
T: +45 89 93 10 00
F: +45 89 93 10 01
M: kamstrup@kamstrup.com

We, Kamstrup A/S declare that this Declaration is issued under our sole responsibility and belongs to the following product: **Kamstrup Pt500 Temperature Sensors** type number 65-00-0xx-xxx or 66-00-0xx-xxx or 65-56-4xx-xxx, serial number 2023/XXXXXXXX, which is in conformity with the latest versions of the relevant UK Regulations, as marked below:

The Restriction of the Use of Certain Hazardous Substances in Electrical and Electronic Equipment Regulations 2012, standard: EN/IEC 63000:2018.


Measuring Instruments Regulations 2016, standards: EN 1434:2007/AC:2007, EN 1434:2015. Applies for products marked with CE marking and supplementary metrology marking according to Article 21 in directive 2014/32/EU.

Module B certificate number: DK-0200-MI004-036.

Notified Body, Module D certificate: FORCE Certification A/S, EU Notified Body number 0200, Park Allé 345, DK-2605 Brøndby. Module D certificate number: DK-0200-MID-D-001.

Date: 2022-12-23, Skanderborg

Senior Vice President, Technology:



Anders Skallebæk

Note: In the event of inconsistency or discrepancy between the English version and any other language version, the English version shall prevail.

No.: 5518515_B1

kamstrup

UK DECLARATION OF CONFORMITY

The UKCA (UK Conformity Assessed) marking is a product marking used for goods being placed on the market in Great Britain (England, Wales and Scotland). It covers goods which previously required the CE marking, known as 'new approach' goods.

Kamstrup A/S
Industrivej 28, Stilling
DK-8660 Skanderborg
T: +45 89 93 10 00
F: +45 89 93 10 01
M: kamstrup@kamstrup.com

We, Kamstrup A/S declare that his Declaration is issued under our sole responsibility and belongs to the following products: **Kamstrup TemperatureSensor 63 / Kamstrup TemperatureSensor 83**, type number 61-63-D0-0XX-XXX or type number 61-83-D0-0XX-XXX, serial number 2023/XXXXXXXX, which are in conformity with the latest versions of the relevant UK Regulations, as marked below:

The Restriction of the Use of Certain Hazardous Substances in Electrical and Electronic Equipment Regulations 2012, standard: EN/IEC 63000:2018.

Measuring Instruments Regulations 2016, standards: EN 1434:2007, EN 1434:2015/A1:2018.


Applies for products marked with CE marking and supplementary metrology marking according to Article 21 in directive 2014/32/EU.

Module B certificate number: DK-0200-MI004-046.

Notified Body, Module D certificate: FORCE Certification A/S, EU Notified Body number 0200, Park Allé 345, DK-2605 Brøndby. Module D certificate number: DK-0200-MID-D-001.

Date: 2022-12-23, Skanderborg

Senior Vice President, Technology:



Anders Skallebæk